CHECKLIST

Fire Door Compliance Check

- [ ] Locate the rating label on the door edge and confirm it is legible
- [ ] Inspect intumescent strips and smoke seals for damage or gaps
- [ ] Test the door closer by opening and releasing the door from various angles
- [ ] Check for alterations such as holes, excessive trimming or replaced hardware
- [ ] Verify the frame carries a matching fire resistance rating
- [ ] Retrieve the installation certificate or contact the installer to obtain one
- [ ] Arrange a surveyor inspection if any component fails the checks above