CHECKLIST

Fire Door Rating Checklist

- [ ] Locate the rating stamped on the door edge or printed on the certification label
- [ ] Check the frame and hardware match the door's test specification
- [ ] Verify intumescent strips and smoke seals remain intact around the perimeter
- [ ] Look for daylight or oversized gaps when the door is shut
- [ ] Ensure no holes, panels or alterations have been made outside the certificated scope
- [ ] Test that the closer brings the door to latch from any open position
- [ ] Record the certificate number and test standard for future reference