CHECKLIST

Fire exit thumb turn lock inspection checklist

- [ ] Rotate the thumb turn through its full range and confirm the bolt retracts completely
- [ ] Inspect the cam for burrs or visible damage
- [ ] Confirm the retaining screw on the door edge remains tight
- [ ] Test that the door latches securely when closed
- [ ] Clean the mechanism and apply graphite powder to the keyway every six months
- [ ] Verify that intumescent pads remain in place around the cylinder
- [ ] Replace the cylinder if resistance increases or cracks appear